



उत्पाद मैनुअल
आई एस 12640 (भाग 1) : 2016/ आईईसी 61008-1 : 2012 के अनुसार
घरेलु और समान प्रयोजनों के लिए भिन्न ओवरकरंट सुरक्षा सहित अवशिष्ट करंट चालित परिपथ
विजोजक (आर सी सी बी एस) भाग 1 सामान्य नियम (दूसरा संशोधन)
के लिए

दस्तावेज संख्या – पीएम/आईएस 12640 (भाग 1)/ IEC 61008-1/3/ मई 2023
भारतीय मानक ब्यूरो की स्कीम-I (अनुरूपता मूल्यांकन) विनियम, 2018 के तहत यह उत्पाद
मैनुअल प्रमाणीकरण के प्रचालन में रीति और पारिश्रिता की सुसंगतता सुनिश्चित करने के लिए सभी
क्षेत्रीय/शाखा कार्यालयों और लाइसेंसी द्वारा संदर्भ सामग्री के रूप में उपयोग किया जाएगा।
बीआईएस प्रमाणीकरण लाइसेंस/ प्रमाणपत्र प्राप्त करने के इच्छुक भावी आवेदकों द्वारा भी इस
दस्तावेज का उपयोग किया जा सकता है।

PRODUCT MANUAL FOR
Residual Current Operated Circuit- Breakers Without Integral Overcurrent
Protection for Household and Similar Uses (RCCBs) Part 1 General Rules
(Second Revision)

ACCORDING TO IS 12640 (Part 1) : 2016/ IEC 61008-1 : 2012

Document No - PM/ IS 12640 (Part 1)/ IEC 61008-1/3/May 2023

This Product Manual shall be used as reference material by all Regional/Branch Offices & licensees to ensure coherence of practice and transparency in operation of certification under Scheme-I of Bureau of Indian Standards (Conformity Assessment) Regulations, 2018 for various products. The document may also be used by prospective applicants desirous of obtaining BIS certification licence/certificate.

भारतीय मानक ब्यूरो
BUREAU OF INDIAN STANDARDS
मानक भवन, ९, बहादुर शाह ज़फ़र मार्ग
Manak Bhawan, 9, Bahadur Shah Zafar Marg
नई दिल्ली- ११०००२
New Delhi – 110002



**PRODUCT MANUAL FOR
RESIDUAL CURRENT OPERATED CIRCUIT BREAKERS
WITHOUT INTEGRAL OVERCURRENT PROTECTION FOR
HOUSEHOLD AND SIMILAR USES (RCCBs)
ACCORDING TO IS 12640(Part 1):2016/IEC 61008-1:2012**

This Product Manual shall be used as reference material by all Regional/Branch Offices & licensees to ensure coherence of practice and transparency in operation of certification under Scheme-I of Bureau of Indian Standards (Conformity Assessment) Regulations, 2018 for various products. The document may also be used by prospective applicants desirous of obtaining BIS certification licence/certificate.

1.	Product	:	IS 12640(Part 1):2016/IEC 61008-1:2012
	Title	:	Residual Current Operated Circuit Breakers Without Integral Overcurrent Protection for Household & Similar Uses (RCCBs)
	No. of Amendments	:	4
2.	Sampling Guidelines:		
a)	Raw material	:	-
b)	Grouping guidelines	:	As per Annex A of IS 12640 (Part 1) : 2016 / IEC 61008-1 : 2012
c)	Sample Size	:	As per Annex A of IS 12640 (Part 1) : 2016 / IEC 61008-1 : 2012
3.	List of Test Equipment	:	Please refer ANNEX – A .
4.	Scheme of Inspection and Testing	:	Please refer ANNEX – B .
5.	Possible tests in a day :	:	Please refer ANNEX – C .
6.	Scope of the Licence :		
	“Licence is granted to use Standard Mark as per IS 12640(Part 1):2016/IEC 61008-1 with the following scope:”		

	Name of the product	Residual Current Operated Circuit Breakers Without Integral Overcurrent Protection for Household & Similar Uses(RCCB)
	Classification	As applicable according to Cl. 4 of IS 12640 (Part 1) : 2016/ IEC 61008-1 : 2012

ANNEX A**List Of Test Equipment***Major test equipment required to test as per the Indian Standard*

S. No.	Test Equipment	Tests used in with Clause Reference
1.	28 Day Test Panel	Cl. 9.8, Cl. 9.22.2
2.	Endurance Panel	Cl. 9.10
3.	HV Test Panel	Cl. 9.7.2, Cl. 9.7.3, Cl. 9.7.7.3
4.	Leakage Current Test	Cl. 9.7.7.3
5.	Glow Wire Test	Cl. 9.14
6.	Climatic Chamber	Cl. 9.7.1, Cl. 9.13, 9.22.1
7.	Data logger & thermometer for temperature measurement	Cl. 9.8, Cl. 9.22.2, Cl. 9.9.3, Cl. 9.9.4
8.	Digital Multi meter	Cl. 9.8, Cl. 9.16
9.	AC/DC Clamp Meter	Cl. 9.8, Cl. 9.9, Cl. 9.10
10.	Insulation Tester	Cl. 9.7.2
11.	RCCB Test Panel – D0 sequence	Cl. 8.5

The above list is indicative only and may not be treated as exhaustive.

ANNEX B

Scheme Of Inspection And Testing

1. LABORATORY- A laboratory shall be maintained which shall be suitably equipped (as per the requirement given in column 2 of Table 1) and staffed, where different tests given in the specification shall be carried out in accordance with the methods given in the specification.

1.1 The manufacturer shall prepare a calibration plan for the test equipment.

2. TEST RECORDS - The manufacturer shall maintain test records for the tests carried out to establish conformity.

3. LABELLING AND MARKING - As per the requirements of IS 12640 (Part 1) : 2016/ IEC 61008-1 : 2012. Further, each RCCB or the carton in which the RCCBs are packed shall carry the identification mark in code or otherwise for traceability. In addition, details of BIS website shall be marked as follows: “For details of BIS certification please visit www.bis.gov.in “.

4. CONTROL UNIT - All the RCCBs of the same fundamental design, as indicated in Annex A of IS 12640 (Part 1) : 2018/ IEC 61008-1 : 2012, manufactured in a shift shall constitute a control unit.

5. LEVELS OF CONTROL - The tests as indicated in column 1 of Table 1 and the levels of control in column 3 of Table 1, shall be carried out on the whole production of the factory which is covered by this plan and appropriate records maintained in accordance with paragraph 2 above.

6. REJECTIONS - Disposal of non-conforming product shall be done in such a way so as to ensure that there is no violation of provisions of BIS Act, 2016

TABLE 1

(1)				(2)	(3)		
Test Details				Test equipment requirement R: required (or) S: Sub-contracting permitted	Levels of Control		
Cl.	Requirement	Test Methods			No. of Sample	Frequency	Remarks
		Clause	Reference				
9.1.3	Routine Tests						
D.2	Tripping test	D.2	IS 12640 (Part 1)	R	Each Piece	—	RCCBs which fail in any of the routine test shallnot be marked. A separate record of such failures shall be maintained with adequate traceability.
D.3	Electric Strength Test	D.3	IS 12640 (Part 1)	R	Each Piece		
D.4	Performance of the test device	D.4	IS 12640 (Part 1)	R	Each Piece		
Test Sequence A							
6	Marking (except indelibility of marking)	6	IS 12640 (Part 1)	R	One	Every Control Unit	—
8.1.1	Mechanical Design (General)	8.1.1	IS 12640 (Part 1)	R	One	Every Control Unit	
8.1.2	Mechanical Design (Mechanism)	8.1.2	IS 12640 (Part 1)	R/S (for Cl. 9.11)	One	Every Control Unit	For compliance to tests as per Cl. 9.11, thefrequency of once in five years on RCCBs of the same fundamental design shall be applicable
6	Indelibility of marking	6, 9.3	IS 12640 (Part 1)	R	One	Once in six months on RCCBs of the same fundamental design	—
8.1.3	Clearance & creepage distances (external parts)	8.1.3, 9.7.7.4.1, 9.7.7.4.2	IS 12640 (Part 1)	R	One		

TABLE 1

(1)				(2)	(3)		
Test Details				Test equipment requirement R: required (or) S: Sub-contracting permitted	Levels of Control		
Cl.	Requirement	Test Methods			No. of Sample	Frequency	Remarks
		Clause	Reference				
8.1.2	Trip-free mechanism	8.1.2, 9.15	IS 12640 (Part 1)	R	One	Once in six months on RCCBs of the same fundamental design	—
8.1.4	Reliability of Screws, current-carrying parts and connections	8.1.4, 9.4	IS 12640 (Part 1)	R	One		
8.1.5	Reliability of Terminals for external conductors	8.1.5, 9.4 & 9.5, Annex-J,K or L	IS 12640 (Part 1)	R	One		
8.2	Protection against electric shock	8.2, 9.6	IS 12640 (Part 1)	R	One		
8.9	Resistance to heat	8.9, 9.13	IS 12640 (Part 1)	S	One		
8.1.3	Clearance & Creepage distances (internal parts)	8.1.3, 9.7.7.4.1, 9.7.7.4.2	IS 12640 (Part 1)	R	One		
8.1.4.4	Resistance to rusting	8.1.4.4, 9.25	IS 12640 (Part 1)	S	One		
8.10	Resistance to abnormal heat and to fire	8.10, 9.14	IS 12640 (Part 1)	S	Three		

TABLE 1

(1)				(2)	(3)		
Test Details				Test equipment requirement R: required (or) S: Sub-contracting permitted	Levels of Control		
Cl.	Requirement	Test Methods			No. of Sample	Frequency	Remarks
		Clause	Reference				
Test Sequence B							
8.1.3	Resistance of the insulation of open contacts and basic insulation against an impulse voltage in normal conditions	8.1.3, 9.7.7.4	IS 12640 (Part 1)	R	Three	Once in six months on RCCBs of the same fundamental design	Refer note 1
9.7.7.5	Verification of the behavior of components bridging the basic insulation	9.7.7.5	IS 12640 (Part 1)	R	Three		
8.1.3, 8.3	Resistance to humidity	8.3, 9.7.1	IS 12640 (Part 1)	R	Three		
8.1.3, 8.3	Insulation resistance of the main circuit	8.3, 9.7.2	IS 12640 (Part 1)	R	Three		
8.1.3, 8.3	Dielectric Strength of the main circuit	8.3, 9.7.3	IS 12640 (Part 1)	R	Three		
8.1.3, 8.3	Insulation resistance and dielectric strength of auxiliary circuits	8.3, 9.7.4	IS 12640 (Part 1)	R	Three		
8.1.3, 8.3	Verification of clearances with the impulse withstand voltage	8.3, 9.7.7.2	IS 12640 (Part 1)	R	Three		

TABLE 1

(1)				(2)	(3)		
Test Details				Test equipment requirement R: required (or) S: Sub-contracting permitted	Levels of Control		
Cl.	Requirement	Test Methods			No. of Sample	Frequency	Remarks
		Clause	Reference				
8.1.3, 8.3	Secondary circuit of detection transformers	8.3, 9.7.5	IS 12640 (Part 1)	R	Three	Once in six months on RCCBs of the same fundamental design	Refer Note 1
8.1.3, 8.3	Capability of control circuits connected to the main circuits	8.3, 9.7.6	IS 12640 (Part 1)	R	Three		
8.4	Temperature rise	8.4, 9.8	IS 12640 (Part 1)	R	Three		
8.16	Reliability at 40°C	8.16, 9.22.2	IS 12640 (Part 1)	R	Three	Once in a year on RCCBs of the same fundamental design	
8.16	Ageing of electronic components	8.16, 9.23	IS 12640 (Part 1)	R	Three		
Test Sequence C							
8.6	Mechanical and electrical endurance	8.6, 9.10	IS 12640 (Part 1)	R	Three	Once in a year on RCCBs of the same fundamental design	Refer Note 1
Test Sequence D							
8.5	Residual Operating characteristic	8.5, 9.9.1, 9.9.2, 9.9.3, 9.9.4	IS 12640 (Part 1)	R	Three	Once in six months on RCCBs of the same fundamental design	Refer Note 1
8.12	Behavior in the case of failure of line voltage	8.12, 9.17	IS 12640 (Part 1)	R	Three		

TABLE 1

(1)				(2)	(3)		
Test Details				Test equipment requirement R: required (or) S: Sub- contracting permitted	Levels of Control		
Cl.	Requirement	Test Methods			No. of Sample	Frequency	Remarks
		Clause	Reference				
8.14	Unwanted tripping Behavior in the case of surge currents	8.14, 9.19	IS 12640 (Part 1)	S	Three	Once in six months on RCCBs of the same fundamental design	Refer Note 1
8.7	Performance at I _{Δm}	8.7, 9.7.7.3, 9.11.2.3a)b)	IS 12640 (Part 1)	S	Three		
8.11	Test device	8.11, 9.16	IS 12640 (Part 1)	R	Three		
8.8	Resistance to mechanical shock and impact	8.8, 9.12	IS 12640 (Part 1)	R	Three	Once in a year on RCCBs of the same fundamental design	
8.13	Non-operating current under overcurrent conditions	8.13, 9.18	IS 12640 (Part 1)	R	Three	Once in six months on RCCBs of the same fundamental design	

TABLE 1

(1)				(2)	(3)		
Test Details				Test equipment requirement R: required (or) S: Sub-contracting permitted	Levels of Control		
Cl.	Requirement	Test Methods			No. of Sample	Frequency	Remarks
		Clause	Reference				
8.7	Verification of the suitability of RCCBs for use in IT systems	8.7, 9.7.7.3, 9.11.2.3c)	IS 12640 (Part 1)	S	Three	Once in five years on RCCBs of the same fundamental design	Refer Note 1
Test Sequence E							
8.7	Coordination at I _{nc}	8.7, 9.7.7.3, 9.11.2.4a)	IS 12640 (Part 1)	S	Three	Once in five years on RCCBs of the same fundamental design	Refer Note 1
8.7	Performance at I _m	8.7, 9.7.7.3, 9.11.2.2	IS 12640 (Part 1)	S	Three		
Test Sequence F							
8.7	Coordination at I _m	8.7, 9.7.7.3, 9.11.2.4b)	IS 12640 (Part 1)	S	Three	Once in five years on RCCBs of the same fundamental design	Refer Note 1

TABLE 1

(1)				(2)	(3)		
Test Details				Test equipment requirement R: required (or) S: Sub-contracting permitted	Levels of Control		
Cl.	Requirement	Test Methods			No. of Sample	Frequency	Remarks
		Clause	Reference				
8.7	Coordination at I _{Δc}	8.7, 9.7.7.3, 9.11.2.4c)	IS 12640 (Part 1)	S	Three	Once in five years on RCCBs of the same fundamental design	Refer Note 1
Test Sequence G							
8.16	Reliability (climatic test)	8.16, 9.22.1	IS 12640 (Part 1)	S	Three	Once in a year on RCCBs of the same fundamental design	Refer Note 1
Test Sequence H, I, J							
8.17	Electromagnetic Compatibility	9.24	IS 12640 (Part 1)	S	Three	Once in five years on RCCBs of the same fundamental design	Refer Note 1

Note-1: In case of failure, repeat testing to be carried out as per Table A.2 of IS 12640 (Part 1) : 2016/ IEC 61008-1 : 2012.

Note-2: Sub-contracting is permitted to a laboratory recognized by the Bureau or Government laboratories empanelled by the Bureau.

Note-3: Levels of control given in column 3 are only recommendatory in nature. The manufacturer may define the control unit/batch/lot and submit his own levels of control in column 3 with proper justification for approval by BO Head.

ANNEX C

Possible Tests in a day

- Tripping Test
- Electric Strength Test
- Performance of the test device
- Indelibility of Marking
- Clearance & Creepage distance (only for item 1 & 3 of Table 5 of IS 12640 (Part 1) : 2016/IEC 61008-1 : 2012
- Trip free mechanism
- Reliability of screws, current carrying parts and connections
- Reliability of terminals for external conductors
- Protection against electric shock
- Verification of resistance of the insulation of open contacts and basic insulation against an impulse voltage in normal conditions
- Verification of the behavior of components bridging the basic insulation
- Capability of control circuits connected to the main circuits
- Residual Operating Characteristics
- Behavior in case of failure of line voltage