



उत्पाद मैनुअल

आई एस 9537 (भाग 8) : 2003 के अनुसार

विद्युत् संस्थापनों के लिए तार नालियाँ - विशिष्टि

भाग 8 एल्युमीनियम मिश्रधातु की दृढ़ चूड़ी रहित तार नालियाँ के लिए

दस्तावेज संख्या - पीएम/आईएस 9537 (भाग 8)/1/ जनवरी 2023

भारतीय मानक ब्यूरो की स्कीम-I (अनुरूपता मूल्यांकन) विनियम, 2018 के तहत यह उत्पाद मैनुअल प्रमाणीकरण के प्रचालन में रीति और पारिश्रिता की सुसंगतता सुनिश्चित करने के लिए सभी क्षेत्रीय/शाखा कार्यालयों और लाइसेंसी द्वारा संदर्भ सामग्री के रूप में उपयोग किया जाएगा। बीआईएस प्रमाणीकरण लाइसेंस/प्रमाणपत्र प्राप्त करने के इच्छुक भावी आवेदकों द्वारा भी इस दस्तावेज का उपयोग किया जा सकता है।

**PRODUCT MANUAL FOR
SPECIFICATION FOR CONDUITS FOR ELECTRICAL INSTALLATIONS
PART 8 RIGID NON-THREADABLE CONDUITS OF ALUMINIUM
ALLOY ACCORDING TO IS 9537 (Part 8) : 2003**

Document No - PM/ IS 9537(Part 8)/ 1/ January 2023

This Product Manual shall be used as reference material by all Regional/Branch Offices & licensees to ensure coherence of practice and transparency in operation of certification under Scheme-I of Bureau of Indian Standards (Conformity Assessment) Regulations, 2018 for various products. The document may also be used by prospective applicants desirous of obtaining BIS certification licence/certificate.

भारतीय मानक ब्यूरो

BUREAU OF INDIAN STANDARDS

मानक भवन, ९, बहादुर शाह ज़फ़र मार्ग

Manak Bhawan, 9, Bahadur Shah Zafar Marg

नई दिल्ली- ११०००२

New Delhi – 110002



PRODUCT MANUAL FOR RIGID NON-THREADABLE CONDUITS OF ALUMINIUM ALLOY ACCORDING TO IS 9537 (Part 8) : 2003

This Product Manual shall be used as reference material by all Regional/Branch Offices & licensees to ensure coherence of practice and transparency in operation of certification under Scheme-I of Bureau of Indian Standards (Conformity Assessment) Regulations, 2018 for various products. The document may also be used by prospective applicants desirous of obtaining BIS certification licence/certificate.

1.	Product	:	IS 9537(Part 8) : 2003
	Title	:	Conduits for Electrical Installations- Rigid Non-Threadable Conduits of Aluminium Alloy
	No. of Amendments	:	NIL
2.	Sampling Guidelines:		
a)	Raw material	:	-
b)	Grouping guidelines	:	Please refer ANNEX – A
c)	Sample Size	:	6 manufacturing lengths
3.	List of Test Equipment	:	Please refer ANNEX – B.
4.	Scheme of Inspection and Testing	:	Please refer ANNEX – C.
5.	Possible tests in a day:		
	(i) Marking as per Cl. 6.1 (ii) Durability of Marking as per Cl. 6.2 (iii) Dimensions as per Cl. 7.1 to Cl. 7.3, Cl. 7.101 (iv) Uniformity of Wall Thickness as per Cl. 7.4 (v) Construction as per Cl. 8 (vi) Bending Test as per Cl. 9.2		
6.	Scope of the Licence :		
	“Licence is granted to use Standard Mark as per IS 9537(Part 8):2003 with the following scope:		
	Name of the product	Conduits for Electrical Installations- Rigid Non-Threadable Conduits of Aluminium Alloy	
	Type	Light/Medium/Heavy Mechanical Stress	
	Nominal Sizes	16mm/20mm/25mm/32mm/40mm/50mm/63mm	
	Any other aspect required as per the Standard	Plain End/ Socket End	

ANNEX A**Grouping Guidelines**

1. The parameters as given below shall be considered for grouping of Rigid Plain Conduits of Insulating Materials as per IS 9537(Part 8):2003 for GOL/Inclusion:

- i.

Group	Nominal Size of Conduits
I	16mm, 20mm, 25mm
II	32mm, 40mm, 50mm, 63mm

- ii. Grade of Mechanical Stress - Light/Medium/Heavy

- iii. Type of End connection- Plain End/ Socket End

2. Further, as per IS 9537(Part 8) : 2003, only conduits of sizes 16 mm, 20mm and 25mm shall be subjected to Bending Test and Collapse Test.
3. Considering the above, conduits of any nominal size from Group I and from each Grade of Mechanical Stress shall be tested to cover all the sizes of conduits in Group I and Group II for that particular Grade of Mechanical Stress. However, if the sample tested is of any nominal size from Group II, GOL/Inclusion shall be considered for all the sizes in Group II only for that particular Grade of Mechanical Stress.
4. Relaxation shall be given to cover plain ended conduits if socket ended conduit is tested.
5. If plain ended conduit is covered in the licence of the manufacturer, addition of socket ended conduit may be considered based on applicable tests for socket end, subject to that the plain conduit of the socket end conduit is carrying BIS Standard Mark.
6. The Firm shall declare the grade of mechanical stress and the nominal size of conduits they intend to cover in the Licence.
7. The Scope of Licence may be restricted based on the Manufacturing and Testing capabilities of the Manufacturer.
8. During the operation of the Licence, BO shall ensure that all the varieties covered in the Licence are tested in rotation, to the extent possible.

ANNEX B**List Of Test Equipment*****Major test equipment essentially required to test as per the Indian Standard***

S. No.	Test Equipment	Tests used in with Clause Reference
1.	Measuring tape	Cl. 7
2.	Vernier Calliper	Cl.7
3.	Gauges for checking minimum & maximum outside diameter	Cl.7
4.	Gauges for checking minimum inside diameter	Cl.7
5.	Gauges for measuring minimum & maximum inside & outside diameter of socket ends	Cl.7
6.	Micrometre	Cl.7
7.	Bending Device	Cl. 9.2
8.	Bending Aid	Cl. 9.2
9.	Deep Freezer	Cl. 9.2
10.	Compression Test Apparatus	Cl. 9.3
11.	Conditioning Chamber	Cl. 9.3
12.	Gauges for measuring minimum inside diameter of conduits after bending	Cl. 9.5
13.	Straps	Cl. 9.5
14.	Ball Pressure Apparatus	Cl. 10
15.	Heating Cabinet	Cl. 10.2
16.	Bunsen burner	Cl. 11
17.	High Voltage Breakdown Test set	Cl. 12
18.	Million Mega Ohm Meter	Cl. 12
19.	Impact Test Apparatus	Cl. 9.4
20.	Stop Watch	Cl. 10.2
21.	Steel Ball	Cl. 10.2

The above list is indicative only and may not be treated as exhaustive.

ANNEX C

Scheme of Inspection and Testing

1. LABORATORY - A laboratory shall be maintained which shall be suitably equipped (as per the requirement given in column 2 of Table 1) and staffed, where different tests given in the specification shall be carried out in accordance with the methods given in the specification.

1.1 The manufacturer shall prepare a calibration plan for the test equipment.

2. TEST RECORDS – The manufacturer shall maintain test records for the tests carried out to establish conformity.

3. LABELLING AND MARKING – In addition to the requirements of IS 9537(Part 8):2003, all such information in code or otherwise for traceability shall be given in the label attached to each bundle of conduits.

4. CONTROL UNIT – All conduits of the same classification and size manufactured in a day shall constitute one control unit.

5. LEVELS OF CONTROL - The tests as indicated in column 1 of [Table 1](#) and the levels of control in column 3 of [Table 1](#), shall be carried out on the whole production of the factory which is covered by this plan and appropriate records maintained in accordance with paragraph 2 above.

5.1 All the production which conforms to the Indian Standard and covered by the licence should be marked with Standard Mark.

6. REJECTIONS – Disposal of non-conforming product shall be done in such a way so as to ensure that there is no violation of provisions of BIS Act, 2016.

TABLE 1

(1)				(2)	(3)		
Test Details				Test equipment requirement R: required (or) S: Sub-contracting permitted	Levels of Control		
Cl.	Requirement	Test Methods			No. of Sample	Frequency	Remarks
		Clauses	Reference				
8	Construction	8	IS 9537(Part 1)	R	Each Conduit	—	—
6.1	Marking	6	IS 9537(Part 8)	R			
6.2	Durability of Marking	6.4	IS 9537(Part 1)	R	Ten	Each Control Unit	The sample shall be collected at random from the production line.
7	Dimensions	7	IS 9537(Part 1), IS 9537 (Part 8)	R	Two	Every Hour (Refer Note 1)	
9.2	Bending test	9.2	IS 9537(Part 1), IS 9537 (Part 8)	R	Three	Each Control Unit	—
9.3	Compression Test	9.3	IS 9537(Part 1), IS 9537(Part 8)	S	Three	Conduits of same classification & size manufactured in a month	
13	External Influence	13	IS 9537(Part 1), IS 9537(Part 8)	S			

Note-1: Firm to have adequate in-process controls to check compliance of this parameter as per the tolerances given in the Indian Standard. However, appropriate records shall be maintained by the manufacturer for evidence of conformity.

Note-2: Levels of control given in column 3 are only recommendatory in nature. The manufacturer may define the control unit/batch/lot and submit his own levels of control in column 3 with proper justification for approval by BO Head.