



उत्पाद मैनुअल
आई एस 2202 (भाग 1):2023 के अनुसार लकड़ी के सपाट दरवाजे के शटर
(ठोस कोर प्रकार) - प्लाईवुड फेस पैनल के लिए

PRODUCT MANUAL FOR WOODEN FLUSH DOOR SHUTTERS
(SOLID CORE TYPE) – PLYWOOD FACE PANELS
ACCORDING TO IS 2202 (PART 1): 2023

विभिन्न उत्पादों के लिए भारतीय मानक ब्यूरो) अनुरूपता मूल्यांकन (विनियम, 2018 की योजना -I के तहत प्रमाणन के संचालन में एकरूपता और पारदर्शिता के लिए इस उत्पाद मैनुअल का उपयोग सभी क्षेत्रीय / शाखा कार्यालयों और लाइसेंसधारियों द्वारा संदर्भ सामग्री के रूप में किया जाएगा। दस्तावेज़ का उपयोग बीआईएस प्रमाणन प्राप्त करने के इच्छुक संभावित आवेदकों द्वारा भी किया जा सकता है।

This Product Manual shall be used as reference material by all Regional/Branch Offices & licensees to ensure uniformity of practice and transparency in operation of certification under Scheme-I of Bureau of Indian Standards (Conformity Assessment) Regulations, 2018 for various products. The document may also be used by prospective applicants desirous of obtaining BIS certification.

1.	मानक संख्या IS No.	:	IS 2202 (Part 1) : 2023
	शीर्षक Title	:	Wooden Flush Door Shutters (Solid Core Type) – Plywood Face Panels
	संशोधनों की संख्या No. of amendments	:	1
2.	नमूना दिशानिर्देश Sampling Guidelines		
a)	कच्चा माल Raw material	:	Please refer to Annex-A Note: This section indicates the requirements for raw material (if specified in the IS) for which compliance is to be established during Grant of Licence/Change in Scope of Licence/ Factory Surveillance
b)	समूहीकरण दिशानिर्देश Grouping Guidelines	:	Please refer to Annex-B
c)	नमूने का परिमाण Sample Quantity	:	2 Flush door shutters for all tests Note: This section indicates the quantity of the sample of the product and/or the raw material (if applicable), required to be sent to the laboratory for testing, for the purpose of Grant of Licence/Change in Scope of Licence/

		Factory Surveillance (incase of market surveillance, effort may be made to procure therequired quantity of product sample, as far as possible since raw material sample may not be available in market)
3.	परीक्षण उपकरणों की सूची List of Test Equipment	: Please refer to Annex-C
4.	निरीक्षण और परीक्षण की स्कीम Scheme of Inspection and Testing	: Please refer to Annex-D
5.	एक दिन में संभावित परीक्षण Possible tests in a day	
	(i) Fittings (Clause 8), (ii) Workmanship and finish (Clause 9), (iii) Dimension and Squareness (Clause 11.1), (iv) General flatness test (Clause 11.2), (v) Local planeness test (Clause 11.3), (vi) Knife test (Clause 11.13), (vii) Impact indentation test (Clause 11.4), (viii) Flexure test (Clause 11.5), (ix) Edge loading test (Clause 11.6), (x) Shock resistance test (Clause 11.7), (xi) Buckling test (Clause 11.8), (xi) Slamming test (Clause 11.9), (xii) Misuse test (Clause 11.10)	
6.	लाइसेंस का दायरा /Scope of the Licence:	
	Licence is granted to use Standard Mark as per IS 2202 (Part 1):2023 with the following scope :	
	Name of the product	Wooden Flush Door Shutters (Solid Core Type) – Plywood Face Panels
	Grade	BWP/MR
	Type and Construction	BD/BN/PD/PN/MD/MN
	Size	• Modular : Size Designations & Thickness • Non-Modular: Size (Height x Width x Thickness), mm

भारतीय मानक ब्यूरो
 BUREAU OF INDIAN STANDARDS
 मानक भवन, ९, बहादुर शाह ज़फ़र मार्ग
 Manak Bhawan, 9, Bahadur Shah Zafar Marg
 नई दिल्ली- ११०००२
 New Delhi – 110002

ANNEX A
Raw Material

Raw Material	Indian Standard
Timber	Timber shall conform to Clause 6.1 of IS 2202 (Part 1):2023.
Plywood	Plywood shall conform to Clause 6.2 of IS 2202 (Part 1):2023.
Cross bands	Cross bands shall conform to Clause 6.3 of IS 2202 (Part 1):2023.
Face veneers	Face veneers shall conform to Clause 6.4 & 6.5 of IS 2202 (Part 1):2023.
Adhesive (MR/BWP grade)	Adhesive shall conform to Clause 6.6 of IS 2202 (Part 1):2023.
Particle boards	Particle boards shall conform to Clause 6.7 of IS 2202 (Part 1):2023.
Medium density Fibre (MDF) board	MDF board shall conform to Clause 6.8 of IS 2202 (Part 1):2023.
Alternative Materials	Alternative Materials shall conform to Clause 6.9 of IS 2202 (Part 1):2023.

ANNEX B
Grouping Guidelines

1. Wooden Flush Door Shutters as per IS 2202 (Part 1) are classified as given below:

a) **Grade of door shutters** – BWP/ MR

b) **Type and Construction**

Construction of Core	Type	Abbreviation
Blockboard	Decorative	BD
	Non-decorative	BN
Particle board	Decorative	PD
	Non-decorative	PN
Medium density fibre board	Decorative	MD
	Non-decorative	MN

c) **Sizes**

Modular (with Designation of Doors) - 8 DS 20/ 8 DS 21/ 9 DS 20/ 9 DS 21/ 10 DS 20/ 10 DS 21/12 DT 20/ 12 DT 21

(D - Door, S - Single shutter, T - Double leaf shutter)

Non-Modular - Sizes other than modular sizes, as agreed to between the manufacturer and the purchaser, may also be permitted; provided, the thickness of shutters in such cases shall be equal to that specified against the nearest higher modular size given at clause (d) below.

d) **Thickness**

The nominal thickness of the shutters shall be 25mm, 30 mm and 35 mm corresponding to each of the sizes given below:

Flush Door Designation	Thickness of Shutter (mm)
8 DS 20/ 8 DS 21	25 or 30
9 DS 20/ 9 DS 21	30
10 DS 20/ 10 DS 21	35
12 DT 20/ 12 DT 21	35

For sizes greater than 12 DT 21, the thickness of such shutters shall be greater than 35 mm and shall be as agreed to between the manufacturer and the purchaser.

2. Considering the above, the grouping guidelines given below shall be followed for GoL/CSoL:
 - a) Modular sizes:
 - (i) Wooden Flush Door Shutters of the highest Size Designations from each Grade, Type and Construction of Core shall be tested for all requirements to cover Shutters of all lower Size designations including the size designation tested for that particular Grade, Type and Construction of Core tested.
 - (ii) Lowest and highest thickness of door shutters shall be tested to include all the intermediate thicknesses of door shutters including the thicknesses tested.
 - b) Non-modular sizes:
 - (i) Wooden Flush Door Shutters of the highest Size (Height x Width) from each Grade, Type and Construction of Core shall be tested for all requirements to cover Shutters of all lower Sizes (Height x Width) including the size tested for that particular Grade, Type and Construction of Core tested.
 - (ii) Lowest and highest thickness of door shutters shall be tested to include all the intermediate thicknesses of door shutters including the thicknesses tested.
3. The Firm shall declare the varieties (i.e. grade, type, construction of core, modular size designations with thickness and non-modular sizes with thickness) of Wooden Flush Door Shutters they intend to cover in the Licence. The Scope of Licence may be restricted based on the Manufacturing and Testing capabilities of the Manufacturer.
4. During the operation of the Licence, BO shall ensure that all the varieties covered in the Licence are tested in rotation, to the extent possible.

ANNEX-C

List of Test Equipment

(INDICATIVE LIST, FOR GUIDANCE ONLY)

S. No.	Tests used in with Clause Reference	Test Equipment
1.	Dimensions and Squareness (Clause 11.1)	- Measuring Tape - Steel Scale - Micrometer - Vernier Calipers - Squareness Gauge - Straight Edge - Feeler Gauge
2.	Adhesive Testing (Clause 6.6)	- Moisture Meter - Stop Watch - Viscosity Cups B-4 Cup /B-6 Cup - Thermometer - Desiccators - IS Sieve - Air Conditioner - Dry /Wet Thermometer - Distilled Water - Electronic Balance - PH Meter - Enamelled Tray
3.	General flatness test (Clause 11.2)	- General Flatness test assembly/fixture with Plump Bob - Feeler Gauge - Spirit Level
4.	Local planeness test (Clause 11.3)	- Local Planeness test assembly/fixture with Dial Gauge - Spirit Level - Filler Gauge
5.	Impact indentation test (Clause 11.4)	- Impact indentation test assembly/fixture with steel ball - Dial gauge - Ball stand
6.	Flexure test (Clause 11.5)	- Flexure test arrangement with Loads
7.	Edge loading test (Clause 11.6)	- Edge loading test arrangement with Loads - Depth gauge
8.	Shock resistance test (Clause 11.7)	- Shock resistance test arrangement - Leather ball
9.	Buckling test (Clause 11.8)	- Buckling resistance test arrangement with Loads - Angle protector
10.	Slamming test (Clause 11.9)	- Slamming Test assembly/fixture with Protractor, Stop watch - Hard wood strips
11.	Misuse test (Clause 11.10)	- Misuse test assembly with angle protector, hard wood strip and loading arrangement

12.	Varying humidity test (Clause 11.11)	- Temperature and humidity control cabinet
13.	End immersion test (Clause 11.12)	- End emersion test arrangements - Door holding arrangement
14.	Knife test (Clause 11.13)	- Knife - Stout table
15.	Glue adhesion test (Clause 11.14)	- Glue Adhesion Test - Water Bath with temperature controller - Humidity Chamber with temperature controller
16.	Screw withdrawal Resistance test (Clause 11.15)	- Tensile Testing Machine with fixture for screw withdrawal - Screws - Dial Gauge - Hot Air Oven temperature controller
17.	Raw material Testing (Clause 6.6)	- Moisture Meter - Stop Watch - Viscosity Cups B-4 Cup /B-6 Cup - Thermometer - Desiccators - IS Sieve - Air Conditioner - Dry /Wet Thermometer - Distilled Water - Electronic Balance - PH Meter - Enamelled Tray

ANNEX D SCHEME OF INSPECTION AND TESTING

1. QUALITY ASSURANCE PLAN

1.1 It is expected that manufacturers (licensees/applicants) will implement a Quality Assurance Plan i.e. a plan of regular testing and in-process controls, designed to ensure that the product bearing the Standard Mark conforms to all requirements of the Indian Standard.

1.2 The manufacturers shall define a Quality Assurance Plan defining the control unit (i.e. lot/batch etc.) and the levels of control (i.e. the frequency and number of samples for conducting the different tests as per the Indian Standard) and submit the same to BIS Branch Office for information. The manufacturer shall comply with the same and maintain test records in accordance with para 2.4.

1.3 RECOMMENDED LEVELS OF CONTROL/CONTROL UNIT:

1.3.1 For the guidance of manufacturers, the recommended definition of control unit: All Flush door shutters of the same grade, type, size and construction manufactured under similar conditions in a day shall be considered as a control unit.

1.3.2 For the guidance of manufacturers in preparing the Quality Assurance Plan, recommended levels of control are given in **Table 1**.

1.3.3 The manufacturer shall ensure inspection and testing as per the Quality Assurance Plan submitted by them on the whole production of the factory which is covered by this plan. Alternatively, the manufacturer has the option of adherence to the quality plan as per levels of control recommended in column 3 of Table 1.

1.4 However, all manufacturers shall ensure compliance of their products to all the requirements of the Indian Standard.

2 ENSURING COMPLIANCE THROUGH TESTING- It is expected that manufacturers (licensees/applicants) will establish a suitably equipped and staffed in house laboratory (In house testing facility) for testing at least those parameters of the Indian Standard which require routine testing for ensuring quality of the product. This includes in-process controls as may be defined and put in place by the manufacturer and testing parameters/requirements which can only be performed in the factory.

2.3 For the guidance of manufacturers, Table 1 giving the recommended levels of control is given below. Column 2 of Table 1 indicates routine tests where test equipment is required in house as “R” or other tests which can be subcontracted as “S”. Subcontracting is permitted to BIS recognized/empanelled laboratory or any other laboratory having valid NABL accreditation as per IS/ISO/IEC 17025.

2.4 For MSME manufacturers, the requirement of maintaining a laboratory/in-house testing facility for routine tests (indicated as “R” in Column 2 of Table 1) is also optional.

2.4.2 MSME manufacturers may utilize common cluster based facilities as per guidelines for the utilization of cluster based test facilities by MSMEs or the provisions of Sharing of testing facilities or get

testing done from BIS recognized/empaneled laboratory or any other laboratory having valid NABL accreditation as per IS/ISO/IEC 17025.

2.5 Large Scale manufacturers shall maintain an in-house laboratory equipped at least with test facilities for routine tests (indicated as “R” in Column 2 of Table 1), where different tests given in the specification shall be carried out in accordance with the method given in the specification. They shall also implement a calibration plan for the in-house test equipment.

2.5.2 Alternatively, in lieu of an in-house laboratory, large scale manufacturers can also utilize the provisions of Sharing of testing facilities as per the Guidelines for Grant of Licence available on BIS website www.bis.gov.in. (Under Conformity Assessment>Product Certification Process). Even for subcontracted tests, provisions for sharing of testing facilities can be utilized.

2.6 TEST RECORDS- The manufacturers maintaining an in-house laboratory or utilizing common cluster based facilities or shared test facilities shall maintain test records for the tests carried out to establish conformity. For the tests being subcontracted to BIS recognized/empanelled laboratory or any other laboratory having valid NABL accreditation as per IS/ISO/IEC 17025, test reports issued by the laboratories shall be available for inspection by BIS.

3 PACKING AND MARKING - The Standard Mark as given in the Schedule of the licence shall be legibly and indelibly marked on any of the edges of door shutters, provided always that the product so marked conforms to all requirements of the specification.

3.1 Marking shall be done as per Clause 14 of IS 2202 (Part 1):2023.

3.2 A consignment of BIS certified wooden flush door shutters confirming to IS 2202 (Pt 1):2023 may be accompanied by a test certificate as given in Annex-1.

3.3 Additional Marking requirements: Each door shutters shall also be marked with the following detail:

a) “For BIS certification details please visit www.bis.gov.in”

4 REJECTION - All the production which conforms to the Indian Standard and covered under the scope of this licence shall be marked with the Standard Mark. Disposal of non-conforming product shall be done in such a way so as to ensure that there is no violation of provisions of BIS Act,2016.

TABLE 1
(ONLY FOR GUIDANCE PURPOSE)

(1)				(2)	(3)		
Test Details				Test equipment requirement R: required (or) S: Sub-contracting permitted	Levels of Control		
Cl.	Requirement	Test Methods			No. of Sample	Frequency	Remarks
		Clause	Reference				
6.1	Timber	6.1	IS 2202 (Part 1)	R	Firm to have adequate in-process controls to check compliance of this parameter as per the requirements given in the Indian Standard. Appropriate records shall be maintained by the manufacturer for evidence of conformity		
6.2	Plywood	6.2	IS 303 IS 710 IS 1328	S	One	Each Consignment	No further testing is required, if material received is ISI Marked and accompanied with the test certificate. For non-ISI marked materials, test report from BIS recognized lab is required.
6.3	Cross-Bands	6.3	IS 303 IS 710	S	One	Each Consignment	
6.4 & 6.5	Face Veneers	6.4 & 6.5	IS 2202 (Part 1) IS 710	S	One	Each Consignment	
6.6	Adhesive	6.6	IS 2202 (Part 1) IS 848	S	One	Each Consignment or each kettle (if manufactured in-house)	
6.9	Alternative Materials (LVL, VLL, MDF HDF, Plywood)	6.9	IS 14616 IS 16171 IS 12406 IS 710/ IS 303	S	One	Each Consignment	
6.7	Particle Board	6.7	IS 2380 (Part 17)	R	One	Each Consignment	Swelling in thickness shall not exceed 5%.
6.8	Medium Density Fibre (MDF) Board	6.8	IS 2380 (Part 17)	R	One	Each Consignment	

7	Construction	7	IS 2202 (Part 1)	R	Firm to have adequate in-process controls to check compliance of this parameter as per the requirements given in the Indian Standard. Appropriate records shall be maintained by the manufacturer for evidence of conformity		
8	Fittings	8	IS 2202 (Part 1)	R			
9	Workmanship and finish	9	IS 2202 (Part 1)	R			
11.1	Dimensions and Squareness test	11.1	IS 2202 (Part 1)	R			
11	General flatness test	11.2	IS 2202 (Part 1) IS 4020 (Part 3)	R	Five	Each control unit	Sample shall be drawn at regular intervals. In case of failure, all shutters covered in control unit shall be tested and only those shutters which are conforming to the requirements shall be marked.
	Local planeness test	11.3	IS 2202 (Part 1) IS 4020 (Part 4)	R			
11.4	Impact indentation test	11.4	IS 2202 (Part 1) IS 4020 (Part 5)	S	One	Once in six months from shutters of each grade, type, size and construction of core	These tests shall also be conducted for every change in construction. In case of failure, marking shall be stopped and reasons for failure shall be investigated. The marking shall be resumed only after two samples pass in the requirements in which failure occurred.
11.5	Flexure test	11.5	IS 2202 (Part 1) IS 4020 (Part 6)	S	One	Once in a year from shutters of each grade, type, size and construction of core	
11.6	Edge loading test		IS 2202 (Part 1) IS 4020 (Part 7)	S	One		
11.7	Shock resistance test	11.7	IS 2202 (Part 1) IS 4020 (Part 8)	S	One		
11.8	Buckling Resistance Test	11.8	IS 2202 (Part 1) IS 4020 (Part 9)	S	One		
11.9	Slamming Test	11.9	IS 2202 (Part 1) IS 4020 (Part 10)	R	One	Once in a week from each grade, type and construction of core	In case of failure of sample, twice the number of samples from next two control units shall be tested and control units shall be accepted on passing of retested samples. Original frequency for testing may be resumed on passing of both control units.

11.10	Misuse test	11.10	IS 2202 (Part 1) IS 4020 (Part 11)	S	One	Once in a year from shutters of each grade, type, size and construction of core	These tests shall also be conducted for every change in construction. In case of failure, marking shall be stopped and reasons for failure shall be investigated. The marking shall be resumed only after two samples pass in the requirements in which failure occurred.
11.11	Varying humidity test	11.11	IS 2202 (Part 1) IS 4020 (Part 12)	S	One		
11.12	End immersion test	11.12	IS 2202 (Part 1) IS 4020 (Part 13)	R	Two	Once in a week from each grade, type and construction of core	In case of failure of sample, twice the number of samples from next two control units shall be tested and control units shall be accepted on passing of retested samples. Original frequency for testing may be resumed on passing of both control units.
11.13	Knife test	11.13	IS 2202 (Part 1) IS 4020 (Part 14)	R			
11.14	Glue adhesion test	11.14	IS 2202 (Part 1) IS 4020 (Part 15)	R			
11.15	Screw withdrawal resistance test	11.15	IS 2202 (Part 1) IS 4020 (Part 16)	S	One	Once in six months from shutters of each grade, type, size and construction of core	These tests shall also be conducted for every change in construction. In case of failure, marking shall be stopped and reasons for failure shall be investigated. The marking shall be resumed only after two samples pass in the requirements in which failure occurred.

(OPTIONAL)

ANNEX-1

XYZ COMPANY

STANDARD MARK

(Registered office address and works address)

TEST CERTIFICATE FOR WOODEN FLUSH DOOR SHUTTERS (SOLID CORETYPE) – PLYWOOD FACE PANELS ACCORDING TO IS 2202 (Pt 1):2023

TEST CERTIFICATE No. _____ DATE _____

TO M/s _____

It is certified that the material described below fully conforms to IS 2202 (Pt 1):2023 and tested in accordance with the Scheme of Inspection and Testing contained in the BIS Certification Marks Licence CM/L_____. The test results of acceptance test requirements are indicated below against the order No:

(PLEASE REFER TO IS 2202 (Pt 1):2023 FOR DETAILS OF SPECIFICATION REQUIREMENTS)

TEST RESULTS

Order No. & Date	Grade	Type & Construc-tion	Size	Date of Mfg/batch No	REQUIREMENTS							REMARKS
					Dimension s and squareness	General flatness	Local planeness	Slamming test	End immersion test	Knife test	Glue adhesion test	

REMARK

SHIPPING ADVICE No.

SIGNATURE:
NAME & DESIGNATION :
FOR XYZ COMPANY