



उत्पाद मैनुअल
दिव्यांगजनों के लिए उपकरण - व्हीलचेयर, फ़ोल्डिंग, छोटा साइज़
आईएस 8086: 2024 के अनुसार

PRODUCT MANUAL FOR
Rehabilitation Equipment —Wheelchairs, Folding, Junior Size
as per IS 8086: 2024

विभिन्न उत्पादों के लिए भारतीय मानक ब्यूरो) अनुरूपता मूल्यांकन (विनियम, 2018 की योजना -I के तहत प्रमाणन के संचालन में एकरूपता और पारदर्शिता के लिए इस उत्पाद मैनुअल का उपयोग सभी क्षेत्रीय / शाखा कार्यालयों और लाइसेंसधारियों द्वारा संदर्भ सामग्री के रूप में किया जाएगा। दस्तावेज़ का उपयोग बीआईएस प्रमाणन प्राप्त करने के इच्छुक संभावित आवेदकों द्वारा भी किया जा सकता है।

This Product Manual shall be used as reference material by all Regional/Branch Offices & licensees to ensure uniformity of practice and transparency in operation of certification under Scheme-I of Bureau of Indian Standards (Conformity Assessment) Regulations, 2018 for various products. The document may also be used by prospective applicants desirous of obtaining BIS certification.

1.	मानक संख्या IS No.	:	IS 8086: 2024
	शीर्षक Title	:	Rehabilitation Equipment —Wheelchairs, Folding, Junior Size
	संशोधनों की संख्या No. of amendments	:	02
2.	नमूना दिशानिर्देश Sampling Guidelines		
a)	कच्चा माल Raw material	:	As per Cl. 6 of IS 8086: 2024
b)	समूहीकरण दिशानिर्देश Grouping Guidelines	:	Each type of Rehabilitation Equipment —Wheelchairs, Folding, Junior Size shall be tested
c)	नमूने का परिमाण Sample Quantity	:	One wheelchair
d)	परीक्षण अनुरोध में घोषित किए जाने वाले पैरामीटर Parameters to be Declared in Test Request	:	- Type - Material of Solid tyres - Size of rear wheels

3.	परीक्षण उपकरणों की सूची List of Test Equipment	:	Please refer ANNEX – A
4.	निरीक्षण और परीक्षण की स्कीम Scheme of Inspection and Testing	:	Please refer ANNEX – B
5.	एक दिन में संभावित परीक्षण Possible tests in a day	:	All tests
6.	लाइसेंस का दायरा /Scope of the Licence:		
“License is granted to use Standard Mark as per IS 8086: 2024 with the following scope:			
Name of the product		Rehabilitation Equipment —Wheelchairs, Folding, Junior Size	
Type		Type 1 / Type 2	
Material of Solid Tyres*		Non- marking resilient rubber (or) ethylene vinyl acetate (EVA) (or) polyurethane (PU) (or) thermoplastic polyurethane (TPU)	
Size of Rear Wheels*		To be declared by the manufacturer	

* - Material used for Solid tyres and size of rear wheels shall be declared by the manufacturer

ANNEX- A
LIST OF TEST EQUIPMENTS
(INDICATIVE LIST, FOR GUIDANCE ONLY)

Sl. No.	Tests used in with Clause Reference	Test Equipment
1	Shape & Dimensions (Cl. No.5.1 & Table 1)	Dial/digital vernier caliper Steel scale Weighing Scale Bevel protractor
2	Test for wheeling (Cl. No 9.1)	Load - 50 kg
3	Hazard running test (Cl. No 9.2)	Load arrangement - 75 kg Test platform with hazard having a vertical drop of 10mm Speedometer for measuring speed
4	Load Test (Cl. No 9.3)	Load - 50 kg Stopwatch

ANNEX B

SCHEME OF INSPECTION AND TESTING

1. QUALITY ASSURANCE PLAN

- 1.1. It is expected that manufacturers (licensees/applicants) will implement a Quality Assurance Plan i.e. a plan of regular testing and in-process controls, designed to ensure that the product bearing the Standard Mark conforms to all requirements of the Indian Standard.
- 1.2 The manufacturers shall define a Quality Assurance Plan defining the control unit (i.e. lot/batch etc.) and the levels of control (i.e. the frequency and number of samples for conducting the different tests as per the Indian Standard) and submit the same to BIS Branch Office for information. The manufacturer shall comply with the same and maintain test records in accordance with para 2.4.

1.3 RECOMMENDED LEVELS OF CONTROL/CONTROL UNIT:

- 1.3.1 For the guidance of manufacturers, the recommended definition of control unit is: Rehabilitation Equipment —Wheelchairs (Folding, Junior Size) manufactured in a day from same consignment of raw material shall constitute a control unit.
- 1.3.2 For the guidance of manufacturers in preparing the Quality Assurance Plan, recommended levels of control are given in Table 1.
- 1.3.3 The manufacturer shall ensure inspection and testing as per the Quality Assurance Plan submitted by them on the whole production of the factory which is covered by this plan. Alternatively, the manufacturer has the option of adherence to the quality plan as per levels of control recommended in column 3 of Table 1.
- 1.4 However, all manufacturers shall ensure compliance of their products to all the requirements of the Indian Standard.

2. **ENSURING COMPLIANCE THROUGH TESTING-** It is expected that manufacturers (licensees/applicants) will establish a suitably equipped and staffed in house laboratory (In house testing facility) for testing at least those parameters of the Indian Standard which require routine testing for ensuring quality of the product. This includes in-process controls as may be defined and put in place by the manufacturer and testing parameters/requirements which can only be performed in the factory.

- 2.1 For the guidance of manufacturers, Table 1 giving the recommended levels of control is given below. Column 2 of Table 1 indicates routine tests where test equipment is required in house as “R” or other tests which can be subcontracted as “S”. Subcontracting is permitted to BIS recognized/empanelled laboratory or any other laboratory having valid NABL accreditation as per IS/ISO/IEC 17025.

- 2.2 **For MSME manufacturers, the requirement of maintaining a laboratory/in-house testing facility for routine tests (indicated as “R” in Column 2 of Table 1) is also optional.**

- 2.2.1 MSME manufacturers may utilize common cluster based facilities as per guidelines for the utilization of cluster based test facilities by MSMEs or the provisions of Sharing of testing facilities or get testing done

from BIS recognized/empaneled laboratory or any other laboratory having valid NABL accreditation as per IS/ISO/IEC 17025.

2.3 Large Scale manufacturers shall maintain an in-house laboratory equipped at least with test facilities for routine tests (indicated as “R” in Column 2 of Table 1), where different tests given in the specification shall be carried out in accordance with the method given in the specification. They shall also implement a calibration plan for the in-house test equipment.

2.3.1 Alternatively, in lieu of an in-house laboratory, large scale manufacturers can also utilize the provisions of Sharing of testing facilities as per the Guidelines for Grant of Licence available on BIS website www.bis.gov.in. (Under Conformity Assessment>Product Certification Process). Even for subcontracted tests, provisions for sharing of testing facilities can be utilized.

2.4 TEST RECORDS- The manufacturers maintaining an in-house laboratory or utilizing common cluster based facilities or shared test facilities shall maintain test records for the tests carried out to establish conformity. For the tests being subcontracted to BIS recognized/empanelled laboratory or any other laboratory having valid NABL accreditation as per IS/ISO/IEC 17025, test reports issued by the laboratories shall be available for inspection by BIS.

3. PACKING AND MARKING - The Standard Mark as given in the Schedule of the licence shall be incorporated legibly and indelibly on each Wheelchairs provided always that the wheelchairs so marked conforms to each requirement of the specification.

3.1 Marking on each Rehabilitation Equipment —Wheelchairs, Folding, Junior Size shall be done as per Cl. 11 of IS 8086: 2024

3.2 **Additional Marking requirements:** The packaging of the wheelchairs shall also be marked with the following additional requirement on it:

a) “For BIS certification details please visit www.bis.gov.in”

3.3 All the production which conforms to the Indian Standard and covered under the scope of this licence shall be marked with the Standard Mark.

4. HYGIENIC CONDITIONS (if applicable) – NA.

5. REJECTION - Disposal of non-conforming product shall be done in such a way so as to ensure that there is no violation of provisions of BIS Act,2016.

TABLE-1

(1)				(2)	(3)		
Test Details				Test equipment requirement R: required (or) S:Sub-contracting permitted	Levels of Control		
Cl.	Requirement	Test Methods			No. of Sample	Frequency	Remarks
		Clause	Reference				
6	Materials	6.1 to 6.9	IS 8086	S	One	Each consignment	No further testing is required if accompanied with the Test Certificate or ISI marked.
5	Shape and Dimension	5.1 & Table 1	IS 8086	R	Firm to have adequate in-process controls to check compliance of this parameter as per the tolerances given in the Indian Standard. However, appropriate records shall be maintained by the manufacturer for evidence of conformity		
7	Requirements						
7.1	Backrest & Seat	7.1.1 7.1.2	IS 8086	R	Firm to have adequate in-process controls to check compliance of this parameter as per the tolerances given in the Indian Standard. However, appropriate records shall be maintained by the manufacturer for evidence of conformity		
7.2	Frame	7.2	IS 8086	R			
7.3	Footrests and Supports	7.3.1 to 7.3.9	IS 8086	R			
7.4	Armrests	7.4	IS 8086	R			
7.5	Hand Rims	7.5	IS 8086	R			
7.6	Brakes	7.6	IS 8086	R			
7.7	Castors	7.7.1 to 7.7.4	IS 8086	R			
7.8	Wheels	7.8	IS 8086	R			
7.9	Clothing Guards	7.9	IS 8086	R			
7.10	Folding Mechanism	7.10	IS 8086	R			
7.11	Lubrication	7.11	IS 8086	R			
8	Finish	8.1 to 8.3	IS 8086	S	One	Once in a month	Test to be carried out based on the type of finish declared
9	Tests						
9.1	Test for wheeling	9.1	IS 8086	R	One	Each Control Unit	
9.2	Hazard running test	9.2.1 to 9.2.5	IS 8086	R	One	Each Control Unit	
9.3	Load test	9.3	IS 8086	R	One	Each Control Unit	
9.4	Test for folding	9.4	IS 8086	R	One	Each Control Unit	